



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on August 23, 2012.

Cello Products Inc.
210 Avenue Road
Cambridge, Ontario N1R 5S9
Canada
519-621-9150

Facility: Cambridge, Ontario, Canada

Pipes and Related Products

Trade Designation	Size	Water Contact Temp	Water Contact Material
[G] Fittings Wrot Copper Fittings	1/8" - 6"	C. HOT	CU

[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193. Weighted average lead content <=0.25%; Solder and flux lead content <=0.2%.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.